

**Portable Appliance Inspection and Test Record**

Customer Name: Fontmell Magna Village Hall  
 Site Address: West Street, Fontmell Magna, Shaftesbury, Dorset. SP7 0JP  
 Report No.: Exported Results 0028  
 Report Date: 15/05/2024  
 User: JGA

Appliance ID:	Appliance:	Date:	Class:	Building:	Location:	Fuse:	Visual:	E/B Res:	Insulation:	Sub_Leakage:	Polarity:	Pass/Fail:
'APPID1130	Hoover	15/05/2024 00:00	2	Village Hall	Fontmell Magna	13A	PASS	N/A	19.99 MR	00.10 mA	N/A	Pass
'APPID1131	Kettle	15/05/2024 00:00	1	Village Hall	Fontmell Magna	13A	PASS	00.10 R	19.99 MR	00.10 mA	N/A	Pass
'APPID1132	Ext lead	15/05/2024 00:00	Ex/Lead	Village Hall	Fontmell Magna	13A	PASS	00.36 R	19.99 MR	N/A	GOOD	Pass
'APPID1133	Ext lead	15/05/2024 00:00	Ex/Lead	Village Hall	Fontmell Magna	13A	PASS	00.36 R	19.99 MR	N/A	GOOD	Pass
'APPID1134	Ext lead	15/05/2024 00:00	Ex/Lead	Village Hall	Fontmell Magna	13A	PASS	00.36 R	19.99 MR	N/A	GOOD	Pass
'APPID1135	Ext lead	15/05/2024 00:00	Ex/Lead	Village Hall	Fontmell Magna	13A	PASS	00.05 R	19.99 MR	N/A	GOOD	Pass
'APPID1136	Ext lead	15/05/2024 00:00	Ex/Lead	Village Hall	Fontmell Magna	13A	PASS	00.16 R	19.99 MR	N/A	GOOD	Pass
'APPID1137	Computer lead	15/05/2024 00:00	2	Village Hall	Fontmell Magna	5A	PASS	N/A	19.99 MR	00.10 mA	N/A	Pass
'APPID1138	Laptop charger	15/05/2024 00:00	2	Village Hall	Fontmell Magna	5A	PASS	N/A	19.99 MR	00.10 mA	N/A	Pass
'APPID1139	Printer lead	15/05/2024 00:00	2	Village Hall	Fontmell Magna	5A	PASS	N/A	19.99 MR	00.10 mA	N/A	Pass
'APPID1140	Heater	15/05/2024 00:00	1	Village Hall	Fontmell Magna	13A	PASS	00.00 R	19.99 MR	00.10 mA	N/A	Pass
'APPID1141	Coffee machine lead	15/05/2024 00:00	2	Village Hall	Fontmell Magna	13A	PASS	N/A	19.99 MR	00.10 mA	N/A	Pass
'APPID1142	Microwave	15/05/2024 00:00	1	Village Hall	Fontmell Magna	13A	PASS	00.08 R	19.99 MR	00.72 mA	N/A	Pass
'APPID1143	Computer lead	15/05/2024 00:00	2	Village Hall	Fontmell Magna	5A	PASS	N/A	19.99 MR	00.10 mA	N/A	Pass



## ELECTRICAL CONTRACTORS

'APPID1144	Fridge	15/05/2024 00:00	1	Village Hall	Fontmell Magna	13A	PASS	00.16 R	19.99 MR	00.10 mA	N/A	Pass
'APPID1145	Microwave	15/05/2024 00:00	1	Village Hall	Fontmell Magna	13A	PASS	00.00 R	19.99 MR	00.39 mA	N/A	Pass
'APPID1146	Christmas lights	15/05/2024 00:00	2	Village Hall	Fontmell Magna	3A	PASS	N/A	19.99 MR	00.10 mA	N/A	Pass
'APPID1147	Hoover	15/05/2024 00:00	2	Village Hall	Fontmell Magna	13A	PASS	N/A	19.99 MR	00.10 mA	N/A	Pass
'APPID1148	DVD player	15/05/2024 00:00	2	Village Hall	Fontmell Magna	5A	PASS	N/A	19.99 MR	00.10 mA	N/A	Pass
'APPID1149	Computer lead	15/05/2024 00:00	2	Village Hall	Fontmell Magna	5A	PASS	N/A	19.99 MR	00.10 mA	N/A	Pass
'APPID1150	Monitor lead	15/05/2024 00:00	2	Village Hall	Fontmell Magna	5A	PASS	N/A	19.99 MR	00.10 mA	N/A	Pass
'APPID1151	Ext lead	15/05/2024 00:00	Ex/Lead	Village Hall	Fontmell Magna	13A	PASS	00.11 R	19.99 MR	N/A	GOOD	Pass